

Minutes of Pre-Bid Meeting

Subject : Supply, installation, Testing and commissioning of 750kVA/600kW silent Diesel Generating Set at NCBS Campus, GKVK Bangalore.

NIT Ref : NCBS/Electrical/E-in-C/Tr-140/2017

Date & Time of Pre-Bid Meeting : 10/01/2018 at 11.30hrs

Venue of Pre-Bid Meeting : NCBS/TIFR, GKVK, Bellary road
Bangalore-560065

The following Bidders' Representatives attended the pre-bid meeting:

Sr.No	Name of the Bidder/Firm	Representative name
1	M/s ESCON Gensets pvt ltd	Mr.Mohamed Riyaz
2	M/s Dolar systems & services pvt ltd	Mr.P.Prakash
3	M/s Sai Shakthi electric (P) ltd	Mr.M.Venkatadri Naidu
4	M/s Powerica Limited	Mr.K.C.Binoy
5	M/s Jeevan Diesels & Electricals ltd	Mr.T.S Suresh
6	M/s Srinivas Electricals	Mr.Srinivas S S
7	M/s Disha Electronics	Mr.Ajay Sharma
8	M/s Kalpaka Power Control	Mr.Senthil.K

The Following NCBS officials were present in the pre-bid meeting:


Sr.No.	Name & Designation
1	Shri. Suresh Kumar A
2	Shri. Rajashekar
3	Shri. S.S.Swain
4	Accounts Officer


Proceeding of the pre-bid meeting is as follows;


1. NCBS officials have explained about the scope of work and purpose of the pre-bid meeting.
2. Thereafter, prospective bidders were requested to put up their queries related to technical specifications and terms and conditions given in the NIT.
3. The queries from prospective bidders were appropriately responded.
4. All bidders were visited the site.

The following points were discussed and agreed during pre-bid meeting.

1. DG set Foundation: This is as per tender document which is bidders scope.
2. Bus bar: Bus bar shall be the Aluminium suitable for the 2500A as per CPWD norms.
3. In Price bid page number 15, under Sub Head 'A', sr.no. iii (d), please refer as 1 no. of Over voltage relay, 1 no. reverse power relay and 1 no Under voltage relay.
4. AMF panel is indoor type
5. Fuel tank thickness: It is as per CPWD 2013
6. In Price bid page number 14, under Sub Head 'A', sr.no. i (j)- site testing of Dg set – Fuel will be supplied by department.
7. Authorization letter from OEM needs to be submitted along with the technical bid.
8. Acoustic enclosure: It should be as per CPCB norms
9. The basic price + GST extra shall be indicated in the boq, however only basic price will be taken in to account for price bid comparative statement.


(Suresh Kumar.A)


(S.S. Swain)


(Rajshekhar.K.S)